

QUESTION AND ANSWER NO. 2

CITY OF DUVALL 2.2 MG Reservoir Improvements

Date of Issue: May 12, 2025
Qualification Due: May 22, 2025 at 12:00pm

Notice to All Plan Holders:

This document includes all submitted questions received by the City prior to Monday, May 12, 2025. This is not considered an addendum and is for clarification purposes only.

CONTRACTOR QUESTION/CLARIFICATION

The City received three questions/clarifications prior to the date above.

1. **Question:** Does the front cover of the SOQ count towards the 10-page limit? The cover includes a project title, a project related picture, and our name and logo.

Answer: *No, a cover page will not count towards the page limit.*

2. **Question:** If seismic evaluation indicates upgrades are required, would they be made as part of this project?

Answer: *Potential seismic upgrades would be included in the project if the budget allows. This should be explored in the planning phase.*

3. **Question:** When was the 615 Booster Pump Station constructed? Was it constructed in 1996 along with the Big Rock Road Reservoir? When was the last time it was rebuilt, or significantly repaired mechanically or control wise?

Answer: *The 615 Booster Pump Station was constructed concurrently with the water reservoir around 1996 with two pumps. A third pump was added in 2000 and a new pump bowl was installed on pump #2 in 2003. Various minor control repairs have occurred periodically at the pump station.*

4. **Follow up from Q&A #1:** Does the City have an active water model? What software do you typically use?

Answer: *The City does have an active water model that is managed through Consor using InfoWater/InfoWater pro software.*